



**UNIVERSITI KUALA LUMPUR
MALAYSIAN INSTITUTE OF INDUSTRIAL TECHNOLOGY**

**FINAL EXAMINATION
JANUARY 2016 SEMESTER**

COURSE CODE	:	JFB 10303
COURSE TITLE	:	ELECTRICAL SYSTEM DESIGN AND INSTALLATION
PROGRAMME LEVEL	:	BACHELOR
DATE	:	24 MAY 2016
TIME	:	2.30 PM – 5.30 PM
DURATION	:	3 HOURS

INSTRUCTIONS TO CANDIDATES

1. Please read the instructions given in the question paper **CAREFULLY**.
 2. This question paper is printed on both sides of the paper.
 3. This question paper consists of **ONE (1)** section.
 4. This question paper consists of **FIVE (5)** questions.
 5. Answer **FOUR (4)** questions only.
 6. Please write your answers on the answer booklet provided.
 7. Table and formula are enclosed as reference.
 8. Please answer all questions in English only.
-

THERE ARE 5 PAGES OF QUESTIONS EXCLUDING THIS PAGE.

Total: 100 Marks

INSTRUCTION: Answer FOUR (4) Question Only

Please use the answer booklet provided.

Question 1

- (a) The "magnitude of the current to be carried by a circuit in normal service" I_b determine by two methods, describe both methods.

(7 marks)

(b)




Figure 1: Connection of the System

A distribution board has a RCCB at 63A with a residual $I_N=0.03A$ and the three final circuit, each protection by a type of C MCB rated 25A as shown in Figure 1. Analyze the operating time of RCCB and MCB under each of the following condition:

- (i) A constant overload of 28A for 1hour in this circuit.
- (ii) A sustained short circuit current of 2000A from live to neutral in the second circuit.
- (c) Based on Question (1b) calculate a high impedance sustained short circuit current of 63.75A from live to earth in the third circuit.

(5 marks)

(5 marks)

(8 marks)

Question 2




Figure 2: Schematic Diagram of the System

- (a) Multi-core, PVC insulated cable connected to 3 phase motor rated at 400V, 15kW, 0.8PF and 90% efficiency. This motor is subjected to frequent start-stop and operating at the ambient temperature at 35° as shown in Figure 2.
- Find the minimum tabulated current are under consideration of IEE Regulation BS60989 with start and stop current rating. (7 marks)
 - Evaluate the size of the conductor are accurate with the current rating for cable in Table 4D2A IEE Regulation. (5 marks)




Figure 3: Diagram of the Circuit

- (b) A heater rated at 230V, 3.5kW is to be installed using twin-with-earth PVC insulated and sheathed cable clip direct in a roof space which has an ambient temperature of 40°C. The circuit is protected by 15A MCB. The cable is bunched with four other twin earth cable for a short distance as shown in Figure 3.

- (i) Calculate the minimum tabulated current rating of the circuit

(5 marks)

- (ii) Evaluate the size of the conductor.

(8 marks)

Question 3

A factory plan to install 1 unit a synchronous motor (3 phase). The motor is required to design a complete circuit in order to control a forward reverse movement with complete installation.

- (a) Find the delta connection base on circuit diagram for this motor.

(8 marks)

- (b) Analyze a power circuit for this connection of circuit to the 3phase power supply.

(8 marks)

- (c) Evaluate a control circuit (schematic diagram) without stop push button.

(15 marks)

Question 4




Figure 4: Connection of Power Outlet

Figure 4 shows the circuit that feeding a group of ten 230V socket outlet. The length of the cable from the protective device to the group of the socket outlet is 17m. The circuit is the single core, copper conductor, PVC insulated cable, clipped direct on nonmetallic surface. The expected average connected load of each socket outlet is 180W at 0.9 power factor. The earthing system is TN-S with measured value Z_e of 0.3Ω and CPC 2.5mm is used. The installation will through an

area where the temperature may reach 35°C. By neglecting the thermal insulation correction factor, and assuming that short circuit current is 1.5kA and $k = 115$. Full load current in this circuit is 5000A.

- (a) Find the design current (I_b) of installation.
(2 marks)
- (b) Find the appropriate size of Miniature Circuit Braker (MCB) to be used by selecting type B.
(2 marks)
- (c) Calculate the minimum tabulated current ($I_{t,min}$) and evaluate appropriate conductor size.
(7 marks)
- (d) Calculate voltage drop of the installation satisfying the requirement 1.5% and create a suitable size of cable based on current rating.
(10 marks)
- (e) Find the clearance time of fault current protection and the appropriate size of conductor as per common practice in 17th Edition IEE Wiring Regulation (BS 7671:2008).
(4 marks)

Question 5




Figure 5: Diagram of Motor Installation

- (a) Find the type of protective device and the requirement breaking capacity for the circuit supply to a 3 phase motor which rated at 20kW, 95% efficiency and 0.85 power factor as shown in Figure 5. This motor has a DOL starter. The main switchboard is fed by a 1-MVA, 22kV/400V transformer which the circuit current is 28.86kA. Find the current rating of the circuit breaker for an ambient temperature 20°C and 40°C respectively.

(8Marks)




Figure 6: Schematic Diagram

- (b) The low voltage supply to high risk block is shown in Figure 6. A short circuit occur inside the final distribution board at the top floor. The fault current is 200A. Calculate the operating time of the incoming protective device at the final DB under the following assumption:
- (i) A type B MCB rated at 32A. (3 marks)
 - (ii) A type 3 MCB rated at 32A. (3 marks)
 - (iii) A RCCB rated at 40A with $I_n = 0.03A$ (4 marks)
- (c) Base on question (5b) evaluate the operating time of MCCB rated at 300A at the main switchboard of the block. (7 marks)

END OF EXAMINATION PAPER

Appendix 1: Table 4D1B

Conductor cross-sectional area	2 cables - single-phase a.c.	3 or 4 cables - three-phase a.c.																	
		Reference Methods 3 & 4 (Enclosed in conduit etc. in or on a wall)	Reference Methods 1 & 11 (Clipped direct or on trays, touching)	Reference Method 12 (Spaced*)	Reference Methods 3 & 4 (Enclosed in conduit etc. in or on a wall)	Reference Methods 1, 11 & 12 (In trefoil)	Reference Methods 1 & 11 (Flat and touching)	Reference Method 12 (Flat spaced*)											
		1	2	3	4	5	6	7	8	9									
mm ²	mV	mV	mV	mV	mV	mV	mV	mV	mV	mV									
1	44	44	44	44	44	38	38	38	38	38									
1.5	29	29	29	29	29	25	25	25	25	25									
2.5	18	18	18	18	18	15	15	15	15	15									
4	11	11	11	11	11	9.5	9.5	9.5	9.5	9.5									
6	7.3	7.3	7.3	7.3	7.3	6.4	6.4	6.4	6.4	6.4									
10	4.4	4.4	4.4	4.4	4.4	3.8	3.8	3.8	3.8	3.8									
16	2.8	2.8	2.8	2.8	2.8	2.4	2.4	2.4	2.4	2.4									
25	1.75	1.80	0.33	1.80	1.75	0.29	1.80	1.50	0.29	1.55	1.50	0.175	1.50	1.50	0.25	1.55	1.50	0.32	1.55
35	1.25	1.30	0.31	1.30	1.25	0.195	1.25	1.25	0.27	1.10	1.10	0.170	1.10	1.10	0.24	1.10	1.10	0.32	1.15
50	0.93	0.95	0.30	1.00	0.93	0.190	0.95	0.93	0.28	0.97	0.81	0.26	0.85	0.80	0.165	0.82	0.80	0.34	0.86
70	0.63	0.65	0.29	0.72	0.63	0.185	0.66	0.63	0.27	0.69	0.58	0.25	0.61	0.55	0.160	0.57	0.55	0.34	0.63
95	0.46	0.49	0.28	0.56	0.47	0.180	0.50	0.47	0.27	0.54	0.42	0.24	0.48	0.41	0.155	0.43	0.41	0.31	0.51
120	0.36	0.39	0.27	0.47	0.37	0.175	0.41	0.37	0.26	0.45	0.33	0.23	0.41	0.32	0.150	0.36	0.32	0.23	0.44
150	0.29	0.31	0.27	0.41	0.30	0.175	0.34	0.29	0.26	0.39	0.27	0.23	0.36	0.26	0.150	0.30	0.26	0.23	0.34
185	0.23	0.25	0.27	0.37	0.24	0.170	0.29	0.24	0.26	0.35	0.22	0.23	0.32	0.21	0.145	0.26	0.21	0.22	0.31
240	0.180	0.195	0.26	0.33	0.185	0.165	0.25	0.185	0.25	0.31	0.17	0.25	0.29	0.160	0.145	0.22	0.160	0.22	0.27
300	0.145	0.160	0.26	0.31	0.150	0.165	0.22	0.150	0.25	0.29	0.14	0.23	0.27	0.130	0.140	0.190	0.130	0.22	0.25
400	0.105	0.130	0.26	0.29	0.120	0.160	0.20	0.115	0.25	0.27	0.12	0.22	0.25	0.105	0.140	0.175	0.105	0.21	0.24
500	0.086	0.110	0.26	0.28	0.098	0.155	0.185	0.093	0.24	0.26	0.10	0.22	0.25	0.086	0.135	0.160	0.086	0.21	0.23
630	0.068	0.094	0.25	0.27	0.081	0.155	0.175	0.076	0.24	0.25	0.08	0.22	0.24	0.072	0.135	0.150	0.072	0.21	0.22
800	0.053	—	—	—	0.068	0.150	0.165	0.061	0.24	0.25	—	—	—	0.060	0.130	0.145	0.060	0.21	0.22
1007	0.042	—	—	—	0.059	0.150	0.160	0.050	0.24	0.24	—	—	—	0.052	0.130	0.140	0.052	0.20	0.21

Appendix 2: 4C1

TABLE 4C1

Correction factors for ambient temperature where protection is against short-circuit

NOTE: This table applies where the associated overcurrent protective device is intended to provide short circuit protection only. Except where the device is a semi-enclosed fuse to BS 3036 the table also applies where the device is intended to provide overload protection.

Type of insulation	Operating temperature	Ambient temperature °C													
		25	30	35	40	45	50	55	60	65	70	75	80	85	90
Rubber (flexible cables only)	60°C	1.04	1.0	0.91	0.82	0.71	0.58	0.41	—	—	—	—	—	—	—
General purpose p.v.c.	70°C	1.03	1.0	0.94	0.87	0.79	0.71	0.61	0.50	0.35	—	—	—	—	—
Paper	80°C	1.02	1.0	0.95	0.89	0.84	0.77	0.71	0.63	0.55	0.45	0.32	—	—	—
Rubber	85°C	1.02	1.0	0.95	0.90	0.85	0.80	0.74	0.67	0.60	0.52	0.43	0.30	—	—
Heat resisting p.v.c.*	85°C	1.03	1.0	0.97	0.94	0.91	0.87	0.84	0.79	0.71	0.61	0.50	0.35	—	—
Thermosetting	90°C	1.02	1.0	0.96	0.91	0.87	0.82	0.76	0.71	0.65	0.58	0.50	0.41	0.29	—
Mineral	70°C sheath	1.03	1.0	0.93	0.85	0.77	0.67	0.57	0.45	0.31	—	—	—	—	—
	105°C sheath	1.02	1.0	0.96	0.92	0.88	0.84	0.80	0.75	0.70	0.65	0.60	0.54	0.47	0.32

NOTE: (i) Correction factors for flexible cords and for 85°C or 150°C rubber-insulated flexible cables are given in the relevant table of current-carrying capacity.

(ii) This table also applies when determining the current-carrying capacity of a cable.

*These factors are applicable only to ratings in columns 2 to 5 of Table 4D1.

Appendix 3: Table 4C2

TABLE 4C2

Correction factors for ambient temperature where the overload protective device is a semi-enclosed fuse to BS 3036.

Type of insulation	Operating temperature	Ambient temperature °C													
		25	30	35	40	45	50	55	60	65	70	75	80	85	90
Rubber (flexible cables only)	60°C	1.04	1.0	0.96	0.91	0.87	0.79	0.56	—	—	—	—	—	—	—
General purpose p.v.c.	70°C	1.03	1.0	0.97	0.94	0.91	0.87	0.84	0.69	0.48	—	—	—	—	—
Paper	80°C	1.02	1.0	0.97	0.95	0.92	0.90	0.87	0.84	0.76	0.62	0.43	—	—	—
Rubber	85°C	1.02	1.0	0.97	0.95	0.93	0.91	0.88	0.86	0.83	0.71	0.58	0.41	—	—
Heat resisting p.v.c.*	85°C	1.03	1.0	0.97	0.94	0.91	0.87	0.84	0.80	0.76	0.72	0.68	0.49	—	—
Thermosetting	90°C	1.02	1.0	0.98	0.95	0.94	0.91	0.89	0.87	0.85	0.79	0.69	0.56	0.39	—
Mineral: Bare and exposed to touch or p.v.c. covered	70°C sheath	1.03	1.0	0.96	0.93	0.89	0.86	0.79	0.62	0.42	—	—	—	—	—
	105°C sheath	1.02	1.0	0.98	0.96	0.93	0.91	0.89	0.86	0.84	0.82	0.79	0.77	0.64	0.55

NOTE: Correction factors for flexible cords and for 85°C or 150°C rubber-insulated flexible cables are given in the relevant table of current-carrying capacity.

*These factors are applicable only to ratings in columns 2 to 5 of Table 4D1.

Appendix 4: Table 4D1A

Conductor cross-section (mm ²)	Reference Method 1 (enclosed in conduit or thermally insulating wall etc.)		Reference Method 2 (enclosed in conduit or a wall etc. in free air)		Reference Method 3 (clipped direct)		Reference Method 4 (as performed when laid horizontally or vertically)		Reference Method 5 (free air)		
	2 cables, single-phase a.c. or d.c.	3 cables, three-phase a.c.	3 cables, single-phase a.c. or d.c.	3 cables, three-phase a.c.	2 cables, single-phase a.c. or d.c. laid and touching	3 cables, three-phase a.c. laid and touching or in foil	2 cables, single-phase a.c. or d.c. laid and touching	3 cables, three-phase a.c. laid and touching or in foil	Horizontal (in conduit)	Vertical (in conduit)	Tin foil
1	2	3	4	5	6	7	8	9	10	11	12
mm ²	A	A	A	A	A	A	A	A	A	A	A
1	11	10.5	13.5	12	15.5	14	—	—	—	—	—
1.5	14.5	13.5	17.5	15.5	20	18	—	—	—	—	—
2.5	19.5	18	24	21	27	25	—	—	—	—	—
4	26	24	32	28	37	33	—	—	—	—	—
6	34	31	41	36	47	43	—	—	—	—	—
10	46	42	57	50	65	59	—	—	—	—	—
16	61	56	76	68	87	79	—	—	—	—	—
25	80	73	101	89	114	104	126	112	146	130	110
35	99	89	125	110	141	129	156	141	181	162	137
50	119	108	151	134	182	167	191	172	219	197	167
70	151	136	192	171	234	214	246	223	281	254	216
95	182	164	232	207	284	261	300	273	341	311	264
120	210	188	269	239	330	303	349	318	396	362	308
150	240	216	300	262	381	349	404	369	456	419	356
185	273	245	341	296	436	400	463	424	521	480	409
240	320	286	400	346	515	472	549	504	615	569	485
300	367	328	458	394	594	545	635	584	709	659	561
400	—	—	546	467	694	634	732	679	852	795	684
500	—	—	626	533	792	723	833	778	982	920	789
630	—	—	720	611	903	826	953	892	1138	1070	935
800	—	—	—	—	1030	943	1086	1020	1265	1188	1031
1000	—	—	—	—	1154	1058	1216	1149	1420	1337	1159

Appendix 5: Table 4B1

TABLE 4B1

Correction factors for groups of more than one circuit of single-core cables, or more than one multicore cable (to be applied to the corresponding current-carrying capacity for a single circuit in Tables 4D1 to 4D4, 4E1 to 4E4, 4F1 and 4F2, 4J1, 4K1 to 4K4, 4L1 to 4L4)**

Reference method of installation (see Table 4A)		Correction factor (C _g)																					
		Number of circuits or multicore cables																					
		2	3	4	5	6	7	8	9	10	12	14	16	18	20								
Enclosed (Method 3 or 4) or bunched and clipped direct to a non-metallic surface (Method 1)		0.80	0.70	0.65	0.60	0.57	0.54	0.52	0.50	0.48	0.45	0.43	0.41	0.39	0.38								
Single layer clipped to a non-metallic surface (Method 1)	Touching	0.85	0.79	0.75	0.73	0.72	0.72	0.71	0.70	—	—	—	—	—	—								
	Spaced*	0.94	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90								
Single layer multicore on a perforated metal cable tray, vertical or horizontal (Method 11)	Touching	0.86	0.81	0.77	0.75	0.74	0.73	0.73	0.72	0.71	0.70	—	—	—	—								
	Spaced* †	0.91	0.89	0.88	0.87	0.87	—	—	—	—	—	—	—	—	—								
Single layer single-core on a perforated metal cable tray, touching (Method 11)	Horizontal	0.90	0.85	—	—	—	—	—	—	—	—	—	—	—	—								
	Vertical	0.85	—	—	—	—	—	—	—	—	—	—	—	—	—								
Single layer multicore touching on ladder supports (Method 13)		0.86	0.82	0.80	0.79	0.78	0.78	0.78	0.77	—	—	—	—	—	—								

* Spaced by a clearance between adjacent surfaces of at least one cable diameter (D_c). Where the horizontal clearances between adjacent cables exceeds 2D_c, no correction factor need be applied.

† Not applicable to Mineral Insulated Cables see Table 4B2.

** When cables having differing conductor operating temperatures are grouped together, the current rating shall be based upon the lowest operating temperature of any cable in the group.

Appendix 6: Table 4B2

Tray Orientation	Arrangement of cables	Number of Trays	Number of multicore cables or circuits					
			1	2	3	4	5	9
Horizontal	Multiconductor cables touching	1	1.0	0.90	0.80	0.80	0.75	0.75
Horizontal	Multiconductor cables spaced†	1	1.0	1.0	1.0	0.95	0.90	—
Vertical	Multiconductor cables touching	1	1.0	0.90	0.80	0.75	0.75	0.70
Vertical	Multiconductor cables spaced†	1	1.0	0.90	0.90	0.90	0.85	—
Horizontal	Single conductor cables trefoil separated††	1	1.0	1.0	0.95	—	—	—
Vertical	Single conductor cables trefoil separated††	1	1.0	0.90	0.90	—	—	—

Appendix 7: Time Current Characteristic of MCB by BS 60898

Test	Type	Test Current	Initial Condition	Test Period	Result
1	B, C, D	$1.13 I_N$	Cold*	$t \geq 1 \text{ h}$ (for $I_N \leq 63 \text{ A}$) $t \geq 2 \text{ h}$ (for $I_N > 63 \text{ A}$)	No tripping
2	B, C, D	$1.45 I_N$	Right after Test 1	$t < 1 \text{ h}$ (for $I_N \leq 63 \text{ A}$) $t < 2 \text{ h}$ (for $I_N > 63 \text{ A}$)	Tripping
3	B, C, D	$2.55 I_N$	Cold*	$1 \text{ s} \leq t \leq 60 \text{ s}$ ($I_N \leq 32 \text{ A}$) $1 \text{ s} \leq t \leq 120 \text{ s}$ ($I_N > 32 \text{ A}$)	Tripping
4	B C D	$3 I_N$ $5 I_N$ $10 I_N$	Cold*	$t \geq 0.1 \text{ s}$ (i.e. instantaneous tripping does not occur)	No tripping
5	B C D	$5 I_N$ $10 I_N$ $50 I_N$	Cold*	$t < 0.1 \text{ s}$ (i.e. instantaneous tripping occurs)	Tripping

* Cold means without previous loading and at 30°C .

Maximum break time of RCCB

0.3s for residual current equal to $1 I_N$.

0.15s for residual current equal to $2 I_N$.

0.04s for residual current equal to $5 I_N$.

0.04s for residual current equal to 500A.

MCCB Standards (BS EN 60497)

Current rating: 10, 16, 20, 32, 40, 50, 63, 80, 100, 200, 300, 400, 630, 800, 1250A

Rated Breaking Capacity: 10, 20, 25, 35, 65, 85 kA (r.m.s)

Appendix 8: 4D2A

TABLE 4D1A

Multicore, p.v.c.-insulated cables, non-armoured
(COPPER CONDUCTORS)


BS 6004
BS 6346

Ambient temperature: 30°C
Conductor operating temperature: 70°C


CURRENT-CARRYING CAPACITY (AMPERES):

Conductor cross-sectional area	Reference Method 4 (enclosed in an insulated wall, etc)		Reference Method 3 (enclosed in conduit or a wall or ceiling, or in trunking)		Reference Method 1 (clipped direct)		Reference Method 1 (on a perforated cable tray) or Reference Method 13 (free air)	
	1	2	3	4	5	6	7	8
mm ²								
1	A	A	A	A	A	A	A	A
1.5	11	10	11.5	13	15	15	13.5	17
2.5	14	13	15	16.5	19	19.5	17.5	22
4	18.5	17.5	20	23	27	27	24	30
6	25	23	27	30	34	36	32	40
10	33	30	36	38	44	46	41	51
16	41	37	45	48	56	58	51	63
25	51	46	56	60	70	73	64	80
35	63	57	69	74	86	89	78	97
50	75	68	82	88	102	106	95	118
70	92	83	100	108	126	131	118	145
95	110	99	119	128	150	156	144	175
120	139	125	149	160	187	194	174	212
150	167	150	179	192	224	231	203	258
185	192	172	206	221	258	266	235	295
240	219	196	235	250	292	300	265	335
300	248	223	265	280	322	330	293	364
360	291	261	297	312	359	367	327	403
400	314	288	319	334	394	402	357	444
400	—	—	402	470	—	634	557	715

Appendix 9: Time Current Characteristic of a typical MCCB



Appendix 10: Graph Prospective Current r.m.s AMPERE



Appendix 10 : Table of Time Current Characteristic of MCB by BS 60898

Test	Type	Test Current	Initial Condition	Test Period	Result
1	B,C,D	1.13In	Cold	+≥1h(for In ≤ 63A) +≥2h(for In > 63A)	No Tripping
2	B,C,D	1.45In	Right after test 1	+≥1h(for In ≤ 63A) +≥2h(for In > 63A)	Tripping
3	B,C,D	2.25In	Cold	1s<+<60s (In≤32A) 1s<+<120s (In>32A)	Tripping
4	B C D	3 In 5In 10In	Cold	+≥0.1s (i.e instantaneous tripping does not occurs)	No Tripping
5	B C D	5In 10In 50In	Cold	+≥0.1s(i.e instantaneous tripping occurs)	Tripping

