



UNIVERSITI KUALA LUMPUR
Malaysia France Institute

FINAL EXAMINATION
SEPTEMBER 2014 SESSION

SUBJECT CODE : FCD20203
SUBJECT TITLE : COOLING LOAD
LEVEL : DIPLOMA
TIME / DURATION : 9.00 AM - 12.00 PM
(3 HOURS)
DATE : 07 JANUARY 2015

INSTRUCTIONS TO CANDIDATES

1. Please read the instructions given in the question paper **CAREFULLY**.
2. This question paper is printed on both sides of the paper.
3. Please write your answers on the answer booklet provided.
4. Answer should be written in blue or black ink except for sketching, graphic and illustration.
5. This question paper consists of **TWO (2)** sections. Section A and B. Answer all questions in Section A. For Section B, answer two (2) question only.
6. Answer all questions in English.
7. Formula is appended.
8. Cooling Load Documentation is provided.

THERE ARE 7 PAGES OF QUESTIONS, EXCLUDING THIS PAGE.

SECTION A (Total: 60 marks)**INSTRUCTION: Answer ALL questions.****Please use the answer booklet provided.****Question 1**

Figure Q1: Floor Plan

- (a) Referring Figure Q1, employing the Cooling Load Check Figure, calculate the capacity of unit to be installed at Bedroom 4. (5 marks)
- (b) By using the answer in question 1(a) and the attached catalogue at Appendix 1, select the suitable unit to be installed at that area. Give at least two (2) reasons for your selection. (15 marks)

Question 2




Figure Q2 (a): Double Storey Terrace House (Intermediate Unit) – First Floor

- (a) Referring to the Figure Q2 (a), find the cooling load for Bedroom 1 employing the Daikin Method in Appendix 2. Its ceiling height is 3000mm. Please ignore bathroom 1.

Specification of construction:

- a) Building : Double-Storey House
- b) Outside wall : Medium construction (concrete block 150mm t)
- c) Window glass : Normal (6mm t) with blind
- d) Floor : Concrete with carpet place on the floor
- e) Ceiling : Only concrete

- f) Lights : Fluorescent lights (40w x 3units)
- g) Persons : 2 (sitting on a chair)
- h) Area : Standard temperature
- i) Door : 1.2m x 2m
- j) Window : 1m x 1.5m

Assume that, ground floor is already cooled.

(15 marks)

- (b) By using the answer in Question 2(a) and the attached catalogue in Appendix 1, select the suitable unit to be installed at that area.

(5 marks)

Question 3




Figure Q3 (a): Heat Transfer in the Building

- (a) Referring Figure Q3 (a), find the total thermal resistance in $\text{ft}^2 \cdot \text{hr} \cdot \text{F} / \text{Btu}$. Given that the surface emittance is 0.05.

(8 marks)




Figure Q3 (b): Heat Transfer thru Wall

(b) Referring to Figure Q3 (b), determine:

- i. Total Thermal Resistance, $\sum R$ in $\text{ft}^2 \cdot \text{hr} \cdot \text{F} / \text{Btu}$
- ii. Overall heat transfer coefficient, U in $\text{Btu} / \text{ft}^2 \cdot \text{hr} \cdot \text{F}$
- iii. Heat Loss, q in Btu / hr

(7 marks)

(2 marks)

(3 marks)

SECTION B (Total: 40 marks)**INSTRUCTION: Answer only TWO questions.****Please use the answer booklet provided.****Question 4**

- (a) Calculate the local time (T_{std}) corresponding to solar noon on 21 March in Bandar Baru Bangi.

(10 marks)

- (b) Calculate the hourly instantaneous sensible load from the occupants in the conditioned space at 10 AM, 11 AM and 12 PM. Knowing that the building is designed for office use and houses for 58 occupants from 8 AM to 4 PM. For most occupied period, the occupants are expected to be seated and performing office work.

(10 marks)

Question 5

- (a) Determine maximum angle of solar altitude, β on 21st March in Bandar Baru Bangi.

(10 marks)

- (b) Find the hourly instantaneous sensible load of the conditioned space (occupied from 8 am to 4 pm) due to the office equipment at 10 AM, 1 PM and 2 PM. The heat gain from the office equipment is 5.0 w/ft². The floor areas for this space are 2800ft².

(10 marks)

Question 6

- (a) Determine the total radiation for roof surface with 45° from vertical at Kota Kinabalu on 21st May facing South 30° East. Given that the value for angle of incidence, θ is 76.70° and direct normal radiation, G_{ND} is 280.56 Btu/hr.ft². You can neglect the Gr radiation.

(10 marks)

- (b) Knowing that the heat gain from the office equipment is 6.5 W/ft² and the floor area for that space is 2750 ft². Determine the hourly instantaneous sensible load of the conditioned space which occupied from 8 am to 4 pm due to the office equipment at 9 AM, 2 PM and 3 PM.

(10 marks)

END OF QUESTION

Appendix 1 : Catalogue**Healthy Series Specifications****SPECIFICATIONS**

MODEL		INDOOR UNIT	YWM 09G	YWM 10G	YWM 15G	YWM 20G		YWM 25G			
		OUTDOOR UNIT	YSL 09C	YSL 10C	YSL 15C	YSL 18C	YSL 20C	YSL 20C	YSL 25C		
TYPE	ESSENTIAL		YWM09G (Ess)	YWM10G (Ess)	YWM15G (Ess)	YWM20G (Ess)	YWM20G (Ess)	YWM25G (Ess)	YWM25G (Ess)		
	ION-AIR		YWM09G (ION)	YWM10G (ION)	YWM15G (ION)	YWM20G (ION)	YWM20G (ION)	YWM25G (ION)	YWM25G (ION)		
TOTAL COOLING CAPACITY		Btu/h	9000	10000	13000	18000	19500	21000	24000		
		W	2640	2930	3810	5275	5715	6155	7035		
TOTAL POWER		W	880	877	1160	1747	2001	2020	2730		
TOTAL CURRENT		A	3.88	3.7	5.09	7.73	8.9	8.92	13.18		
POWER SOURCE		V/Ph/Hz	220 - 240 / 1 / 50								
INDOOR UNIT	AIR FLOW		cmm/ctm	7.79 / 275	8.78 / 310	9.77 / 345	14.44 / 510		18.41 / 650		
	DIMENSION	HEIGHT	mm	260	260		304				
		WIDTH	mm	799	899		1062				
		DEPTH	mm	198	198		222				
	WEIGHT		kg	10	12		16				
	CONTROLLER TYPE			LCD REMOTE CONTROLLER							
	CONDENSATE DRAIN SIZE		mm	16			20				
	AIR FILTER	Essential		SARANET							
		ION-AIR		SARANET + ANTI MICROBIAL + TITANIUM OXIDE							
	AIR TREATMENT	Essential		-							
		ION-AIR		NEGATIVE IONS							
OUTDOOR UNIT	AIR FLOW		cmm/ctm	18.4 / 650	24.4 / 860	27.5 / 970	34.0 / 1200	38.0 / 1340			
	DIMENSION	HEIGHT	mm	495	540		648		750		
		WIDTH	mm	600	700		855		855		
		DEPTH	mm	245	250		328		328		
	WEIGHT		kg	28	32		57	59	62		
	PIPE	TYPE			FLARE						
		SIZE	LIQUID	mm/in	6.35 / 1/4					9.52 / 3/8	
			GAS	mm/in	9.52 / 3/8		12.7 / 1/2	15.88 / 5/8			
REFRIGERANT TYPE & CONTROL			R22 / CAPILLARY TUBE (OUTDOOR)								

- All specifications are subjected to change by the manufacturer without prior notice.
- All units are being tested and comply to ARI 210 / 240.
- YWM 10G is ordered based on project basis only.

Appendix 2 : Daikin Table (Must be return with answer booklet)

					Date :			
Company :					Name of person			
Address:					in charge			
Name of room					Room area (w')			m ²
Floor :					Room Volume : (Area)			m ³
Items				A	Cooling			
					coef B	C = A x B	coef.f	Load Q = f X C
Wall faced to the outdoor				m ²			1	
				m ²				
				m ²				
				m ²				
				m ²				
Roof				m ²			Coefficient of Heat	
				m ²				
Window glass				m ²				
				m ²				
				m ²				
Partition			AREA	m ²			1	
				m ²				
				m ²				
Ceiling				m ²				
Floor				m ²				
Outdoor air	Invasion of outdoor air	Room Vol.		m ³				Area corr.1.0
Heat generation in the room	Person	Number						1
	Light	Electric light		kw	860		Rate of using	1
		Fluorescant light		kw	1000			1
		Electric apparatus		kw	860			1
				kw	860			1
	SH	equipment		m ³ /h				
		person		m ³ /h				
btu/h = kcal/hr x 3,97				Total cooling load (kcal/hr)				
								0,7
				Total cooling load in btu/hr				

Appendix 3 : Formula:

	1ft	$= 12\text{inch}$
	1 m	$= 3.28\text{ ft}$
	1 hr	$= 15^\circ$
	1°	$= 60'$
	R	$= l/c \text{ or } \Delta x/k \text{ where } \Delta x = \text{thickness}$
	U	$= 1/R \text{ or } 1/\sum R$
	Q	$= UA \Delta T$
	t_{sol}	$= t_{\text{std}} - (L_{\text{std}} - L_{\text{loc}}) 4\text{min}/^\circ + E_t$
	H	$= t_{\text{sol}} - 12:00$
	$\sin \beta$	$= \cos l \cos h \cos d + \sin l \sin d$
	$\cos \phi$	$= (\sin \beta \sin l - \sin d) / (\cos \beta \cos l)$
	γ	$= \phi \pm \psi$
	$\cos \theta$	$= \cos \beta \cos \gamma \sin \alpha + \sin \beta \cos \alpha$
	G_{ND}	$= A/e^{(B/\sin \beta)}$
	G_{D}	$= G_{\text{ND}} \cos \theta$
	G_{R}	$= G_{\text{th}} \rho F_{\text{wg}}$
	F_{wg}	$= (1 - \cos \Sigma) / 2, \text{ where } \Sigma = 90 - \alpha \text{ (}\alpha = 0 \text{ for horizontal)}$
	G_{d}	$= (C)(G_{\text{ND}})$
	G_{t}	$= G_{\text{D}} + G_{\text{d}} + G_{\text{R}} \text{ or } G_{\text{t}} = G_{\text{D}} + G_{\text{d}}$
	L_{std}	$= 120^\circ \text{E}$
	Bangi	$= L_{\text{loc}} = 101^\circ 48' \text{E}, l = 2^\circ 56' \text{N}$
	Pulau Pinang	$= L_{\text{loc}} = 100^\circ 38' \text{E}$
	Johor Bahru	$= L_{\text{loc}} = 103^\circ 55' \text{E}, l = 1^\circ 28' \text{N}$
	Kuching	$= L_{\text{loc}} = 110^\circ 19' \text{E}, l = 1^\circ 28' \text{N}$
	Kota Bahru	$= L_{\text{loc}} = 102^\circ 15' \text{E}, l = 7^\circ 48' \text{N}$
	Kota Kinabalu	$= L_{\text{loc}} = 116^\circ 05' \text{E}, l = 5^\circ 59' \text{N}$
	Malacca	$= L_{\text{loc}} = 102^\circ 18' \text{E}$
	Q_{wall}	$= U \times A \times \text{CLTD corr}$
	Q_{roof}	$= U \times A \times \text{CLTD corr}$
	CLTD corr	$= (((\text{CLTD} + L_{\text{m}}) \times 5/9) \times K) + (25.5^\circ \text{C} - T_{\text{i}}) + (T_{\text{o}} - 29.4^\circ \text{C})$
	L_{m}	$= \text{Correction Latitude}$
	K	$= \text{Correction of color, black} = 1, \text{light color} = 0.5$
	T_{i}	$= \text{Inside temperature}$
	$^\circ \text{F to } ^\circ \text{K}$	$= \text{multiply by } 5/9$
	English to S.I unit (U value)	$= \text{multiply by } 5.678 \text{ (W/m}^2 \cdot \text{K)} / \text{(Btu/hr.ft}^2 \cdot \text{F)}$
	T_{o}	$= \text{Outdoor Temperature} - (\text{RH} \times \text{Temperature Range})$
	Q_{cond}	$= U \times A \times \text{CLTDcorr}$
	CLTDcorr	$= (\text{CLTD} \times 5/9) + (25.5^\circ \text{C} - T_{\text{i}}) + (T_{\text{o}} - 29.4^\circ \text{C})$
	Q_{sol}	$= A \times \text{SC} \times \text{SHGF} \times \text{CLF}$
	Q_{app}	$= A \times q_{\text{appl}} \times \text{CLF}$
	Q_{light}	$= A \times q_{\text{light}} \times \text{CLF}$
	Q_{occ}	$= \text{No.of Occupants} \times q_{\text{occ}} \times \text{CLF}$