



**UNIVERSITI KUALA LUMPUR
Malaysia France Institute**

**FINAL EXAMINATION
SEPTEMBER 2014 SESSION**

SUBJECT CODE : FCD20303
SUBJECT TITLE : DUCTING AND PIPING SYSTEM
LEVEL : DIPLOMA
**TIME / DURATION : 9.00 AM – 12.00 PM
(3 HOURS)**
DATE : 31 DECEMBER 2014

INSTRUCTIONS TO CANDIDATES

- 1. Please read the instructions given in the question paper CAREFULLY.**
 - 2. Please write your answers on the answer booklet provided.**
 - 3. Answer should be written in blue or black ink except for sketching, graphic and illustration.**
 - 4. This question paper consists of TWO (2) sections. Answer ALL questions in section A, and 2 questions in Section B.**
 - 5. Duct calculator is allowed to perform duct sizing.**
 - 6. The drawings need to be returned with the answer booklet.**
 - 7. Answer all questions in English.**
-

THERE ARE 6 PAGES OF QUESTIONS, EXCLUDING THIS PAGE AND APPENDIXES.

SECTION A**INSTRUCTION: Answer ALL questions.****Please use the answer booklet provided.****Question 1**

Appendix 1 shows a food court floor layout. There is an open air mechanical plant room to accommodate the water-cooled chiller, cooling towers and pumps for the air conditioning system of the food court. Four (4) air handling unit (AHU) rooms are located at each corner of the building. The food court is designed for a maximum occupancy of 640 pax. There are various type of food provided in the food court as shown in the drawing. The air conditioning system installed for the food court shall be the water-cooled chilled water system. The ceiling height is 12 ft and the space above the plaster ceiling is approximately 30 inches.

- (a) Referring Appendixes 1 & 2, estimate
- i. the total supply air (cfm) and return air (cfm) for each area for the whole floor.
(10 Marks)
 - ii. the cooling capacity (Btu/hr) for each area for the whole floor.
(10 Marks)

Question 2

Assuming the cooling capacity for the whole building is 4,600,000 Btu/hr, sketch your proposed ducting layout in a single line diagram complete with duct dimensions and air diffusers/grilles location for the whole floor for its air conditioning system.

(20 Marks)

Question 3

- (a) Based on the assumption in Question 2, sketch your proposed piping layout complete with pipe dimension in a single line diagram for the chilled water system. (10 Marks)
- (b) Show typical connection for
- i. Water-cooled chiller (5 Marks)
 - ii. Chilled water pump (5 Marks)

SECTION B

INSTRUCTION: Answer TWO (2) questions ONLY.

Question 4

Based on your proposed ducting layout in Question 2,

- (a) Calculate the total external static pressure (" w.g) for the air conditioning ducting system for each AHU.

(15 Marks)

- (b) Select the correct AHU model from the catalogue provided based on your calculation above.

(5 Marks)

Question 5

Based on your proposed piping layout in Question 3,

(a) Calculate the total head (ft w.g) for the chilled water pump.

(15 Marks)

(b) Select the correct chilled water pump from the catalogue provided based on your calculation above.

(5 Marks)

Question 6

During testing and commissioning of the AHU installed in the food court, your technicians have collected the following data and submitted to you as the HVAC engineer. Based on the test report,


(a) Fill in the spaces labeled with (a), (b) and (c). (6 Marks)


(b) Analyse and comment on the system. (14 Marks)

AIR HANDLING UNIT (AHU) TEST SHEET				
	Manufacturer	-	Serial No.	-
	Type	-	Model No.	-
F	Size (MM)	-	Pitch Angle	-
A		Unit	Design	Test
N	Volume	CFM	38,000	34,900
	Speed	R.P.M	909	910
	Manufacturer	TECO		Output HP
M	Type	TEFC		15
O	Serial No	H112300987		Frame No.
T	Voltage, V	415		Running Current
O		Design		Test
R	Speed	R.P.M	(c)	1,455
D	Manufacturer	BANDO		Fan Pulley Dia. (")
R	Type	V-BELT		8
I	Belt Size	C35		Fan Shaft Dia. (mm)
V	No. Of Belt	3		38
E				Motor Pulley Dia. (")
S	Manufacturer	TELEMECANIQUE		5
T	Type	AUTO-TRANS		Motor Shaft Dia. (mm)
A	O/Load Setting	23 A		38
R				
T				
E				
R				
REMARKS:-				
INSTRUMENT USED (Ref. No.)				
* -Suction Pressure + Discharge Pressure ΔP Differential Pressure Fan No.				

END OF QUESTION

Appendix 2





COOLING LOAD

UniKL - MALAYSIA
FRANCE INSTITUTE

Table 1: Design Cooling Load Check Figure:

DESIGN AND COOLING LOAD CHECK FIGURES																														
Applications	Occupancy Sq Ft / Person			Lighting Watts / Sq Ft			Fresh CFM / Person			Air CFM / Sq Ft			Room Sensible Btuh / Sq Ft			Room Total Btuh / Sq Ft			Grand Total Btuh / Sq Ft			Refrigeration Sq Ft / Ton*			Supply Air CFM / Sq Ft					
	Lo	Avg	Hi	Lo	Avg	Hi	Lo	Avg	Hi	Lo	Avg	Hi	Lo	Avg	Hi	Lo	Avg	Hi	Lo	Avg	Hi	Lo	Avg	Hi	Lo	Avg	Hi	Lo	Avg	Hi
Apartments (Flats)	150	100	50	1.0	2.0	4.0	25	35	40	.25	.35	.50	15	25	45	20	30	50	30	40	60	400	300	200	.75	1.25	1.75	1.25	1.5	2.5
	15	10	5	1.0	2.0	3.0	5.0	15	30	.50	1.5	2.5	25	35	50	45	55	70	60	80	120	200	150	100	1.25	1.5	2.5			
Auditoriums, Theaters																														
Educational Facilities	30	25	20	2.0	4.0	6.0	5.0	7.5	10	.20	.30	.40	25	40	55	35	50	65	45	60	80	275	200	150	1.0	1.4	1.8	1.4	1.8	2.1
	75	60	40	2.0	3.0	6.0	10	15	20	.20	.40	.60	30	40	55	35	45	65	45	60	75	275	200	160	1.0	1.4	1.8	1.4	1.8	2.1
	20	15	10	1.5	3.0	4.5	7.5	10	15	.40	.60	.80	25	45	65	35	60	75	55	80	110	225	150	110	1.0	1.5	2.1			
Factories	50	35	25	3.0	4.5	6.0	5.0	10	15	.10	.25	.50	20	45	75	30	60	85	50	80	130	240	150	90	1.0	2.25	3.0	2.25	3.0	3.0
	200	150	100	9.0	10.0	12.0	5.0	10	15	.05	.10	.15	35	55	75	40	60	80	80	120	200	150	100	100	1.5	2.75	3.0	2.75	3.0	3.0
	300	250	200	15.0	15.0	60.0	5.0	10	15	.03	.08	.10	75	115	155	80	120	160	120	150	200	100	80	60	3.0	4.0	6.5	4.0	6.5	6.5
	20	15	10	1.0	1.5	2.0	5.0	10	15	.50	.75	1.0	30	35	50	40	50	70	60	85	120	200	150	100	1.0	1.1	1.4	1.1	1.4	1.4
Hospitals	100	60	40	1.0	2.0	3.0	75	90	100	.75	1.6	2.5	15	35	50	20	40	55	60	120	165	200	100	75	1.0	1.7	2.0	1.7	2.0	2.0
	130	100	65	2.0	3.0	4.0	10	20	30	.25	.75	1.5	10	15	35	15	20	40	30	45	100	400	275	120	.75	1.2	1.7	1.2	1.7	1.7
	150	100	50	2.0	5.0	10.0	20	30	50	.20	.50	1.0	25	45	60	30	55	70	45	70	100	275	175	120	1.0	1.5	2.0	1.5	2.0	2.0
	150	100	50	2.0	4.0	6.0	5.0	7.5	10	.10	.20	.30	20	30	50	25	35	55	30	45	70	400	275	175	1.0	1.1	1.7	1.1	1.7	1.7
	150	100	50	2.0	4.0	6.0	20	25	30	.25	.40	.60	20	40	60	25	45	65	40	60	80	300	200	150	1.0	1.4	2.0	1.4	2.0	2.0
Offices	150	125	100	4.0	6.0	8.0	20	25	30	.25	.40	.60	25	50	75	30	55	80	40	75	90	300	175	135	1.0	1.7	2.4	1.7	2.4	2.4
	125	100	75	4.0	6.0	8.0	10	15	20	.15	.25	.40	20	35	50	25	40	55	30	45	60	400	250	150	1.0	1.2	2.3	1.2	2.3	2.3
	125	100	75	4.0	6.0	8.0	10	15	20	.15	.25	.40	15	20	30	20	25	35	25	30	40	475	400	300	.75	1.0	1.1	1.0	1.1	1.1
	45	30	15	4.0	6.0	8.0	20	30	50	.40	1.0	1.5	30	55	80	40	65	90	60	85	120	200	150	100	1.0	1.8	2.7	1.8	2.7	2.7
	25	20	15	1.5	1.7	2.0	10	15	20	.50	.75	1.0	30	35	50	40	50	70	60	85	120	200	150	100	1.25	1.5	2.0	1.5	2.0	2.0
Shopping Centers	45	40	25	3.0	5.0	9.0	7.5	15	20	.20	.50	1.0	25	35	55	30	40	60	50	60	80	250	200	150	1.25	1.5	2.0	1.5	2.0	2.0
	40	30	20	3.0	4.0	5.0	5.0	7.5	10	.10	.20	.25	20	30	45	25	35	50	35	45	60	325	275	200	1.0	1.4	1.75	1.4	1.75	1.75
	40	25	20	4.0	6.0	9.0	5.0	7.5	10	.15	.25	.35	25	35	45	30	40	50	40	50	60	300	250	200	1.0	1.5	2.0	1.5	2.0	2.0
	80	50	40	2.0	4.0	6.0	5.0	5.0	7.5	.05	.10	.15	15	25	35	20	30	40	30	40	50	400	300	250	.80	1.0	1.2	1.0	1.2	1.2
	40	30	25	2.0	3.0	4.0	10	15	20	.25	.35	.50	30	35	45	40	45	55	60	65	75	200	180	160	1.25	1.5	2.0	1.5	2.0	2.0
	40	25	20	3.0	4.0	6.0	5.0	7.5	10	.15	.25	.35	25	35	45	30	40	50	40	50	60	300	250	200	1.0	1.4	2.0	1.4	2.0	2.0
Specialty Shops	60	40	30	1.0	1.5	2.0	5.0	7.5	10	.10	.20	.30	10	15	25	15	20	30	25	30	40	500	400	300	.75	1.2	1.5	1.2	1.5	1.5
	60	50	40	2.0	3.0	4.0	5.0	7.5	10	.10	.20	.30	25	35	45	30	40	50	40	50	60	300	250	200	1.2	1.4	2.0	1.4	2.0	2.0

* Refrigeration loads are for entire application. ‡ Includes other equipment loads expressed in watts/sq ft.
 † Air quantities shown are for all-air systems. ** Air quantities for heavy manufacturing areas are based on supplementary means to remove excessive heat